

BUILDING WRAP OVERLAPS
MEMBRANE MINIMUM 2"

CLADDING MINIMUM 2"
ABOVE DECK SURFACE

WEATHERDEK MEMBRANE
FULLY ADHERED

90° INSIDE WALL FLASHING
(OPTIONAL)

← MIN SLOPE 1/4" : 12"

6" minimum

PERMABASE® CEMENT BOARD
UNDERLAYMENT

MINIMUM 5/8" T&G PLWOOD
REFER TO WEATHERDEK SUBSTRATE
PREPERATION DETAILS FOR FURTHER INFO

WD
42

WEATHERDEK INSIDE EDGE DETAIL
FOR CLASS A FIRE RATED ASSEMBLY

NOTE: AS A SUPPLIER OF MATERIALS ONLY ADS WEATHERDEK DOES NOT ASSUME RESPONSIBILITY FOR ERRORS IN DESIGN OR SITE CONDITIONS. SUITABILITY OF ALL DETAILS SHOULD BE CONFIRMED BY THE ARCHITECT, CONTRACTOR OR OWNERS REPRESENTATIVE.

Project:	CLASS A FIRE RATED ASSEMBLY		
Title:	TYPICAL INSIDE EDGE DETAIL		
Date:	30/11/16	Drawing No:	WD-42
		Scale:	NTS



ADS Weatherdek Canada Ltd.
600 Adams Rd Kelowna BC
V1X 7S1 Canada
Tel: (250) 765-5575
Fax: (250) 765-5548
www.weatherdek.com

NOTE: